



October 30, 2015

Town of Clinton  
43 Leigh Street  
Clinton, New Jersey 08809

Attn: Richard D. Phelan  
Public Works/Business Administrator

Re: Town of Clinton, County of Hunterdon, State of New Jersey  
Third Quarter 2015  
Quarterly Letter of Water Availability  
Our Project No.: SCE-3765

Dear Mr. Phelan:

Suburban Consulting Engineers, Inc. (SCE) offers the following Letter of Water Availability to the Town of Clinton Water Department as a planning tool that may be used by interested parties requesting information of water availability.

The following water availability calculation has been based on a firm capacity calculation as defined by the NJDEP in N.J.A.C. 7:10-11.6(a), using a peak daily demand as defined herein and prescribed under N.J.A.C. 7:10-11.4(a)(7).

Water Availability as of October 30, 2015: **21,457 gallons per day (GPD)**

The above water availability determination is based on actual water system demand and supply conditions, and also incorporates all valid water reservations up to the date of this determination.

Future water system reservation applicants are cautioned that the water availability described herein is subject to variation, and this letter in no way represents a commitment to serve or a guarantee of allocation for a project at the time of application for water reservation.

Should you have any questions, please feel free to contact me.

Very truly yours,  
**SUBURBAN CONSULTING ENGINEERS, INC.**

Andrew S. Holt, PE, PP, CME  
Water System Consulting Engineer

c: Clinton Water Committee  
Richard Cushing, Clinton Attorney